BOARD OF PUBLIC WORKS

TIM WATTS, President JOHN NEER, Vice President JERRY EDWARDS J.D. KING RENITA WALDRON, Secretary

MACON MUNICIPAL UTILITIES



106 West Bourke P.O. Box 569 Macon, Missouri 63552-0569

Telephone (660) 385-3173 Fax (660) 385-6554

STEPHANIE WILSON, General Manager

August 17, 2010

Ms. Rebecca Webber Director, Air and Waste Management Division U.S. Environmental Protection Agency 901 N. 5th Street, Kansas City, KS 66101 REC'D AUG 2 4 2010

APCO

Mr. James Kavanaugh, Director Air Pollution Control Program Missouri Department of Natural Resources PO Box 176 Jefferson City, MO 65102

RE: NESHAP Initial Notification

Macon Municipal Utilities - Power Plant

Facility ID: 2141 NAICS Code: 221112

Dear Ms. Webber and Mr. Kavanaugh:

On March 3, 2010, the United States Environmental Protection Agency adopted final amendments to the National Emission Standards for Hazardous Air Pollutants for Reciprocating Internal Combustion Engines, 40 C.F.R. Part 63 Subpart ZZZZ. These amendments were effective on May 3, 2010. Pursuant to Section 63.6645(a) and Section 63.9(b), Macon Municipal Utilities submits the following information as its Initial Notification:

- Name and address of the owner/operator:
 Macon Municipal Utilities, P. O. Box 569, Macon, MO 63552, slucas@gommu.com
 (660) 385-2514
- Address of the affected source (i.e. the physical location of the engine(s) subject to Subpart ZZZZ):
 404 Vine Street, Macon, MO 63552
- 3. Identification of the relevant standard and compliance date: Subpart ZZZZ standards for existing RICE at area sources and May 3, 2013.

Ms. Rebecca Webber Mr. James Kavanaugh August 17, 2010 Page 2

- 4. Description of the affected source:
 Nordberg TSGL, 2110 SC, 7675 HP
 Worthington SWCGO-16, 6918 HP
 Caterpillar 3512, 1543 HP
- 5. Types of HAPs emitted by affected source: Benzene, toluene, xylenes, 1,3-butadiene, formaldehyde, acetaldehyde, acrolein, some polycyclic aromatic hydrocarbons and other trace organic compounds.
- 6. Major or Area Source: Area.

If you have any questions regarding the above, please do not hesitate to contact Scott Lucas, slucas@gommu.com, (660) 385-2514

Sincerely,

Scott Lucas

pc: MDNR Regional Field Office